

USED OIL



Used Oil/Fuel/ Transmission Filter Management

- **Puncture and drain filters** into used oil or used fuel containers for 24 hours before storing them.
- **All fuel filters can be managed** with used oil filters once they have been drained.
- **Keep drained filters in dedicated aboveground containers** that do not leak.
- **Clearly label containers** as follows:
 - Used oil filters only = **Used Oil Filters**
 - Both used oil filters and fuel filters = **Used Oil and Fuel Filters**
 - Fuel filters only = **Used Fuel Filters**
- **Keep containers on concrete** or another surface that oil cannot pass through.
- **Keep containers closed** or otherwise protected from the weather.
- **Recycle through a used oil filter transporter and processor** that is registered and approved by the FDEP. *Call the FDEP Hazardous Waste Regulation Section at (850) 245-8707 for a list of approved used oil filter transporters and processors.*

A GUIDE TO Managing Used Oil



Small Quantity Generator Program
(727) 464-7500

www.pinellascounty.org/utilities

Funding provided by Pinellas County Solid Waste, produced in cooperation with the Pinellas County Communications Department. 3,000 copies were printed at a cost of \$252.00 or \$0.084 each. Pinellas County complies with the Americans with Disabilities Act. To obtain accessible formats of this document, please call (727) 464-4062 (V/TDD). Printed on recycled paper 7/14.



**SMALL QUANTITY
GENERATOR PROGRAM**

Used Oil Management

- **Label all containers** (including tanks, drums, dollies, buckets and pans) with the words "Used Oil."
- **Keep containers in good condition** with no visible leaks, severe rusting, apparent structural defects or deterioration.
- **Close, cover or otherwise protect from the weather** all containers and tanks stored outside.
- For tanks and containers that are not double-walled, provide **secondary containment*** that has the capacity to hold 110% of the volume of the largest container or tank.
- **Recycle used oil** through a licensed transporter that has an EPA ID number and is registered with the FDEP. *Call the FDEP Hazardous Waste Regulation Section (850) 245-8707 for a list of approved used oil transporters.*
- **Keep receipts** from your used oil hauler/disposal facility to demonstrate that your used oil has been properly handled.

Used Oil Sorbent Management

De minimus quantities of oil sorbent material can be disposed of at the Pinellas County Solid Waste facility with prior approval. Only sorbent used to clean up automotive fluid is accepted. Sorbent material must be either cellulose- or polypropylene-based; clay and silica absorbents are prohibited. Please call (727) 464-7500 for a Special Waste profile.

Secondary Containment

Secondary containment units must meet or exceed the 110% secondary containment requirement.

- **Containers that are 55 gallons or less** stored inside a structure on an oil-impermeable floor will meet this requirement if any leaks would remain in the structure.
- **For larger containers**, the building structure can meet the secondary containment requirements if:
 - the container(s) is in good condition;
 - the container(s) is not stored near a doorway leading outside or on a surface that slopes toward an outside doorway or drain that leads to the environment;
 - the floor surface is in good condition and is oil-impermeable;
 - the walls connect to the floor; and
 - there is sufficient volume to collect the used oil if it spills.
- **Portable collection containers** (regardless of size) that have wheels, are typically emptied within 24 hours, and are stored on an oil-impermeable surface inside a structure will meet the secondary containment requirement.



examples

Secondary Containment Vessels



This label is provided for your convenience to place on containers of used oil.