Pinellas County

Building & Development Review Services

INSTALLATION COMPLIANCE LETTER
For WINDOWS, DOORS & SHUTTERS

PERMIT #

JOBSITE ADDRESS:

- Fastener Size, Type and Spacing for Frame to Bucking, Structure, Mullions and other required connections are per product approvals.
- Fastener Size, Type and Spacing for Hinges, Strike Plates, Astragal Plates and Receivers, Thresholds and other required connections are per product approvals.
- All operable parts (window sashes, door leaves, locks, etc.) function and perform as intended by the manufacturer.
- All required bucks are installed per product approvals, and shim spaces on all sides of unit are no greater than ¼".
- All required weatherproofing, flashings, sealants and caulk are installed according to the Florida Building Code and Manufacturer's Instructions.

By signing this document, I attest all products installed follow the above requirements and in accordance with the Florida Building Code, Florida Product Approvals and the Manufacturer's Instructions for a complete installation.

Printed Name:

Signature:

Date:

440 Court Street
Clearwater, FL 33756
Phone (727) 464-3888
Fax (727) 453-3256
V/TDD (727) 464-4062
Pinellas.gov